

10- ATTACHMENT: Circuit Map

AREA SUBJECT TO DISPATCHERS BULLETIN NO 22
When a Red Flag Warning is in effect the line or line section will not be re-energized following a lockout until the line or line section, subject to Bulletin 22 restriction has been completely patrolled between the source station or stations and the fault.

